

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-1249:104 Page 1 of 1

CATEGORY: Control Unit (Household)

LISTEE: CADDX-CADDI Controls, Inc, 1420 North Main Street, Gladewater, TX 75647
Contact: *Carol Rucker (903) 845-6941 Ext 128 FAX (903) 845-6811

DESIGN: Models NX-8, NX8E combination household fire and burglary alarm control unit. Refer to listee's printed data sheet for additional detailed product description and operational considerations. System components:

NX-8, NX8E	Control Unit
NX-124, NX-116, NX-108, NX-1208E	Keypad
EOL33, EOL68	End-of-line Resistors
NX-003, NX-003C	Enclosure
NX-216, -216E	Zone Expander
NX-508, -508E	Output Module
NX-507, -507E	Relay Module
NX-148, NX-1308, NX-1316, NX-1324	Keypad
NX-148E NX-1192E, NX-1248E, X-1448E	
NX1448E, NX1308E, NX1316E, NX1324E,	
NX108E, NX116E, NX124E	

RATING: 120 VAC primary, 16.5 VAC secondary; 12 VDC standby

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. The system must have the secondary power supply capable of operating the system for at least 24 hours (battery standby) in the normal condition and followed by not less than 4 minutes of alarm as required by code.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as household fire alarm control unit for use with separately listed compatible initiating and indicating devices. The control unit can generate the three pulse temporal code pattern fire alarm signal (for total evacuation) as required per NFPA 72, 1996 Edition.

NOTE:

1. For household system, **Fire Alarm Verification** (delay of fire alarm signal) feature shall NOT be used in California. This feature shall not be programmed into the control unit.
2. Burglary and other non-fire functions were not examined.

*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**